

APPROVALS / LOGIC NOTE

Project	Krisumi Sales Lounge, Sector-36A, Gurgaon
Subject	Approval Note for HT Line repair work (Post Facto Approval)
Contractor Name	M/s Green India Services
Date	30-08-2025
Document Reference NO.	Krisumi/HR&Admin/25-26/HT Line repair/0009

The requisition was received from HR & Admin Team for HT Line repair work on dated 28th August 2025 at Krisumi Sales Lounge. This work already executed at site by M/s Geen India Services.





S.No.	Description	Unit	Qty	Rate	Amount	Remark
Fault Date 28th August 2025						
1	ST joint - 3x95 Sqm	Nos	2	10500	21000	Repair on dated 28th Aug. 2025
2	Fault3x95 sqmm Cable	Mtr	5	1350	6750	
3	Fuse, Jumper and Patrolling Charges	Job	1	4000	4000	
Total					31,750	
GST extra as applicable						

Terms & Conditions :





A) 100% Payment shall be released after completion of works

The payment for the work will be consumed from Admin/Expense -R&M budget

Budget	Total Admin Expense Budget	20,00,000
	Already Allocated	6,81,859
	This Approval	31,750
	Balance Amount Excluding GST	12,86,391

			
Rashim Gandotra	Gaurav Sethi	Ashok Kumar	Manu Gupta

Approved By

			
Kunal Rishi	Kurumi Nagasaka	Yuji Kato	Akash Khurana

Krishan Chand Jat

From: Suraj Parkash
Sent: 30 August 2025 14:34
To: Krishan Chand Jat
Cc: Abhishek Tomar
Subject: FW: HT line breakdown due to horticulture tree shifting work.
Attachments: External Mail :

Dear Krishan San,

Please prepare logic note

Warm Regards,



Suraj Parkash

General Manager - Procurement & Contracts

Email: suraj.parkash@krisumi.com

Mobile: 9780062262

Sector 36A, Gurugram



Website: www.krisumi.com | Take a walkthrough from home: www.krisumiexperience.com



Please consider the environment before printing this email

Notice to recipient: This e-mail is meant for only the intended recipient of the transmission, and may contain information of Krisumi Corporation that is confidential and/or privileged. If you received this e-mail in error, any review, use, dissemination, distribution, or copying of this e-mail is strictly prohibited. Please notify us immediately of the error by return e-mail and please delete this message from your system. Thank you in advance for your cooperation.

From: Abhishek Tomar <abhishek.tomar@krisumi.com>

Sent: Saturday, August 30, 2025 12:32 PM

To: Suraj Parkash <suraj.parkash@krisumi.com>

Cc: Rashim Gandotra <rashim.gandotra@krisumi.com>; Gaurav Sethi <gaurav.sethi@krisumi.com>; Ashok Kumar <ashok.kumar@krisumi.com>; Sanjeet <sanjeet@krisumi.com>

Subject: RE: HT line breakdown due to horticulture tree shifting work.

Dear Suraj San,

Refer to the attached email and quotation provided by **Green India** for the HT Line repair work carried out on **28-Aug-2025**.

You are requested to kindly process the approval note at the earliest.

Repairs and Maintenance:-
Expense Budget - 20,00,000
Already Allocated- 6,81,859.39
Balance Amount- 13,18,140.61

Please note same has been already communicated and approve by Gourav Sethi San.

Warm Regards,



Abhishek Tomar
Senior Executive – Administration

Email: abhishek.tomar@krisumi.com

Mobile: 9977350542

Sector 36A, Gurugram



Website: www.krisumi.com | Take a walkthrough from home: www.krisumiexperience.com

Notice to recipient: This e-mail is meant for only the intended recipient of the transmission, and may contain information of Krisumi Corporation that is confidential and/or privileged. If you received this e-mail in error, any review, use, dissemination, distribution, or copying of this e-mail is strictly prohibited. Please notify us immediately of the error by return e-mail and please delete this message from your system. Thank you in advance for your cooperation.

From: Ashok Kumar <ashok.kumar@krisumi.com>

Sent: 28 August 2025 17:36

To: Sanjeet <sanjeet@krisumi.com>

Cc: Abhishek Tomar <abhishek.tomar@krisumi.com>; Rashim Gandotra <rashim.gandotra@krisumi.com>; Gaurav Sethi <gaurav.sethi@krisumi.com>

Subject: RE: HT line breakdown due to horticulture tree shifting work.

Approved for repair..

Pl call the vendor and get the HT line repaired on top priority..

Ask the vendor to submit quotation at approved rates, one power supply restored.

Warm Regards,



Ashok Kumar
Assistant General Manager – Facility Management

Email: ashok.kumar@krisumi.com

Mobile: +91 9810256162

Sector 36A, Gurugram



Website: www.krisumi.com | Take a walkthrough from home: www.krisumiexperience.com



Please consider the environment before printing this email

Notice to recipient: This e-mail is meant for only the intended recipient of the transmission, and may contain information of Krisumi Corporation that is confidential and/or privileged. If you received this e-mail in error, any review, use, dissemination, distribution, or copying of this e-mail is strictly prohibited. Please notify us immediately of the error by return e-mail and please delete this message from your system. Thank you in advance

From: Sanjeet <sanjeet@krisumi.com>
Sent: 28 August 2025 17:33
To: Ashok Kumar <ashok.kumar@krisumi.com>
Cc: Abhishek Tomar <abhishek.tomar@krisumi.com>
Subject: HT line breakdown due to horticulture tree shifting work.

Dear sir,

Please find the attached photos,
For your information, Our HT cable got faulty today date 28/08/2025; Time 16:50. So main power supply breakdown and DG power on till issue solved.
Please give approval for vender.

Reason: on horticulture tree shifting work cable punctured by the JCB at two places and main gate gang operated switch (GO) jumper and fuse blast. Photos are attached above.

Warm Regards,



Sanjeet
Sr.Engineer – Maintenance
Email: sanjeet@krisumi.com
Mobile: 9213248611 Ext. 130
Sector 36A, Gurugram



Website: www.krisumi.com | Take a walkthrough from home:
www.krisumixperience.com



Please consider the environment before printing this email

Krishan Chand Jat

From: Green India <greenindiaservices22@gmail.com>
Sent: 29 August 2025 15:25
To: Sanjeet
Cc: Abhishek Tomar; Ashok Kumar
Subject: External Mail :
Attachments: krisumi 2908.pdf

Dear Sir,

Please find the attached proposal for electrical work.

Thanks
Manish

M/s GREEN INDIA SERVICES

Haryana, 122016

TEL: 7982164727

Email:- greenindiaservices22@gmail.com

Proposal for Electrical work.

To,	M/s Krisumi Corporation Pvt Ltd.	Refenence	GIS/2024-25/2907
	Sec-36A, Gurgaon	Date	29-Aug-25
		Customer Ref	by Mail
		Email ID:-	
		K.Attention	

Dear Sir,
We acknowledge with thanks receipt of your above mentioned enquiry, we have pleasure submitting our Quotation/ offer for the same with Terms & conditions:-

Auth. Dealer:-

S.NO.	Item description	Unit	Qty.	Make	Total Wt	Rate(Rs)	Amount(In Rs)	Stock Availabil
1	3x95 ST Joint	Nos	2			10500.00	21000.00	
2	3x95 Sqmm Cable	Meter	5			1350.00	6750.00	
3	Fuse , jumper and patrolling charges.	Job	1			4000.00	4000.00	
							0.00	
		Sub Total	8		0		31750.00	
		Disc	0.00%				0.00	
		Freight	0.00%				0.00	
		Ex.Duty	0.00%				0.00	
		GST	18.0%				5715.00	
		Local Handling Ch.					0.00	
		R.Off	0.0%				0.00	
		G.Total					37465.00	

TERMS & CONDITIONS:

Rates	F.O.R basis at Site.	Rubber Gasket	NA.
Note:-	Installation Charges Extra.	TPI Charges	As above.
CST/VAT	Already Calculated as above.	Insurance	NA.
FREIGHT	Inclusive in quoted prices.	Delivery	As above.
Payments		Validity	5 days

BANK DETAIL

Thanking You,
Yours Truly

For GREEN INDIA SERVICES