

**ECOTECH SERVICES INC...**

(Analytical Laboratory Division - A Govt. Approved Test House )  
 Accredited By:-NABL-ISO/IEC-17025:2017,ISO:9001:2015,ISO:14001:2015 &  
 OHSMS:45001:2018 |Laboratory:-Plot No.99, G.No.4, Navlu Colony, Railway Station  
 Road Ballabgarh-Faridabad-121004

(Haryana).Tel.+91-129-4630926,9650160159,9911378912  
 E-mail:- ecofbd@yahoo.com,info@ecotechservices.in ,www.ecotechservices.in

MSME -UDYAM-HR-03-0021507 | Format Code No.ESI/ALD/NABL/34  
 GSTIN:06AIHPC6825A1ZS {State Code: HR (06) } SAC CODE: 998346

**Bill To:**

M/s Krisumi Corporation Pvt. Ltd  
 Sector-36A , Near Village - Sihi Dwarka  
 Expressway ,Gurgaon - Haryana -122004  
 GSTIN NO. 06AAECV0565A1ZR

**Tax Invoice**

Date: 26 November 2022  
 Invoice No.: ESI/22-23/0502  
 Order No.: ESI/22-23/0594  
 Salesperson: R.Chauhan

Ship To:  
 Sector-36A , Near Village - Sihi Dwarka  
 Expressway ,Gurgaon - Haryana -122004  
 GSTIN NO. 06AAECV0565A1ZR

Qty	Item	Description	Unit Price	Tax	Total
1	ESI0142	Const. water testing as per IS: 456 :-Ph,Acidity,Alkalinity,Organic Solids, Inorganic Solids,Chloride,Sulphate ,Suspended material .	Rs.2,000.00	GST@18%	Rs.2,000.00

GATE IN  
 NO. ....  
 DATE: 28/11/22  
 KRISUMI CORPORATION  
*[Signature]*

Subtotal Rs.2,000.00  
 CGST@9% Rs.180.00  
 SGST@9% Rs.180.00  
**Total Rs.2,360.00**  
 Balance Due Rs.2,360.00

Note:- 01 STP Outlet water sample received on 23/11/2022.

**Terms & Conditions :**

Type of Services: Technical Testing and Analysis Services. SAC CODE :998346  
 PAN Number: AIHPC6825A.  
 BANK : AXIS BANK LTD ,A/C. 911020037661668,IFS CODE- UTIB0000039 (RTGS, IMPS & NEFT)  
 Branch: Ballabgarh -SCO 40, Sector-7, Ballabgarh-Faridabad-121006.  
 Payment by Cheque/Bank draft /on line net banking beneficiary Name "ECOTECH SERVICES INC." FARIDABAD  
 This Tax Invoice Issued under GST Act-2017 (Govt. of India)  
 All disputes will subject to Faridabad court only.  
 Under the Section -15 of MSMED -Act-2006(Payment Terms-Make Payment with in 15 days of acceptance of Goods or Services.

*[Signature]*  
 for ECOTECH SERVICES INC...  
 (Auth.Signatory)



# ECOTECH SERVICES INC... ( Analytical Laboratory Division )

ISO : 9001 : 2015, ISO : 14001 : 2015 | OHSMS - ISO : 45001 : 2018 Certified.  
Members of Association of Indian Laboratories (AOIL) & IAM SME of India.

Plot No. 99, Gali No. 4, Navlu Colony, Railway Road, Ballabgarh - 121004, FARIDABAD (INDIA)  
Phone : +91-129-2213418, Mobile : 9650160159  
E-mail : ecobd@yahoo.com, info@ecotechservices.in  
Website : www.ecotechservices.in

## TEST REPORT

<b>Test Report Issued To:-</b> <b>M/s Krisumi Corporation Pvt. Ltd</b> Sector-36A , Near Village - Sihi Dwarka Expressway , Gurgaon - Haryana -122004	<b>Test Report No.</b>	<b>0011736</b>
	<b>Date of Report</b>	<b>26/11/2022</b>
	<b>Work Order No.</b>	<b>ESI/22-23/0594</b>
	<b>Period of testing</b>	<b>23/11/2022 to 26/11/2022</b>
	<b>Type of Sample</b>	<b>STP Treated Water</b>
	<b>Date of Received</b>	<b>23/11/2022</b>
	<b>Sample Received By.</b>	<b>Ms. Vandana</b>
	<b>Customer Ref.</b>	<b>ESI/22-23/0594</b>
<b>Description of Sample.</b>	One water sample was received by us on 23/11/2022.	
<b>Sample Code /Locations.</b>	STP -Treated Water Sample M/s Krisumi Corporation Pvt. Ltd.	

### Test Results.

Sr. No.	Test Parameters	Unit	Test Results	Specification, standard (method) or technique used.	Permissible Limits as per IS:456:2000
1	pH	-	7.45	IS:3025(Part-11)	Not less than 6.0
2	Acidity	To neutralize 100 ml	0.2ml	IS:3025 (Part-22)	To neutralize 100 ml sample of water, using Phenolphthalein as an indicator, it should not Require more than 5 ml of 0.02 normal NaOH.
3	Total Alkalinity	To neutralize 100 ml	3.1ml	IS:3025 (Part-23)	To neutralize 100 ml sample of water, using the mixed indicator, it should not Require more than 25 ml of 0.02 normal H2SO4
4	Organic Solids	mg/l	180	IS:3025 (Part-18)	200max.
5	Inorganic Solids	mg/l	736	IS:3025 (Part-18)	3000max.
6	Sulphates as SO4	mg/l	102	IS:3025 (Part-24)	400max.
7	Chloride as Cl	mg/l	370	IS:3025 (Part-32)	2000max.
8	Suspended matter	mg/l	2.0	IS:3025 (Part-17)	2000max.

**Remarks/Opinion:-** The above tested parameters are under the specified limits as per IS: 456:2000 and water sample confirm as per IS:456:2000 clause 5.4 for construction purpose.

#### Conditions:-

- ✓ The above mentioned results relates to the tests specified by the customer for the given sample.
- ✓ The test report shall not be reproduced except in full, without the written approval of the Laboratory.
- ✓ This test report shall not be used in any advertising media or as evidence in the Court of Low without prior written consent of Laboratory.
- ✓ The test sample will be disposed off after two weeks from the date of issue of report

----End of report----

