

Tax Invoice

ENVI ECOTECH SERVICES PRIVATE LIMITED

(Formerly Ecotech Services INC. "Since 2008")Accred- NABL,ISO:9001,14001&45001.

1st Floor,P.No.99, G.No.4, Navlu Colony, Railway Station Ballabgarh

Faridabad-121004 (Haryana).Tel.+91-129-4630926,9650160159,9911378912

E-mail:- ecofbd@yahoo.com,info@ecotechservices.in ,www.ecotechservices.in

MSME -UDYAM-HR-03-0076916 | CIN No.U71200HR2023PTC116170

GSTIN:06AAHCE8517A1ZX {State Code: HR (06) } SAC CODE: 998346

Date:

8 July 2024

Invoice No.:

EES/24-25/0271

Order No.:

EES/24-25/0314

Salesperson:

R.Chauhan

Tracking Ref No.:

Mr. Rambir Ji

9818882358

Bill To:

M/s Krisumi Corporation Pvt. Ltd

Sector-36A , Near Village - Sihi Dwarka Expressway ,Gurgaon -
Haryana -122004

GSTIN NO. 06AAECV0565A1ZR

Ship To:

Sector-36A , Near Village - Sihi Dwarka Expressway ,Gurgaon -
Haryana -122004

GSTIN NO. 06AAECV0565A1ZR

Qty	Item	Description	Unit Price	Tax	Total
1	ESI0142	STP- Outlet - Const. water testing as per IS: 456 :-Ph,Acidity,Alkalinity,Organic Solids, Inorganic Solids,Chloride,Sulphate ,Suspended material .	Rs.2,000.00	GST@18%	Rs.2,000.00

Subtotal	Rs.2,000.00
CGST@9%	Rs.180.00
SGST@9%	Rs.180.00
Total	Rs.2,360.00
Balance Due	Rs.2,360.00

Note :- 01 STP Treated Water sample received on 06/07/2024.

Terms & Conditions:

1.Type of Services: Technical Testing and Analysis Services. SAC CODE: 998346

2 PAN Number: AAHCE8517A

3.BANK : HDFC BANK LTD ,A/C 50200089009739,IFS CODE- HDFC0002685 (RTGS, IMPS & NEFT)

4.Branch: HDFC BANK LTD ,SFC-41 Sector-03 ,Faridabad.

5.Payment by Cheque/Bank draft /on line net banking beneficiary Name " ENVI ECOTECH SERVICES PVT.LTD."

6.This Tax Invoice Issued under GST Act-2017 (Govt. of India)

7.All disputes will subject to Faridabad court only.

8. Under the Section -15 of MSMED -Act-2006(Payment Terms-Make Payment within 15 days of acceptance of Goods or Services.

8/7/2024
5-6-8
on 8/7/2024

all
AK

for Envi Ecotech Services Pvt. Limited
R. Chauhan
(Auth.Signatory)



TEST REPORT

Test Report Issued To:- M/s Krisumi Corporation Pvt. Ltd Sector-36A , Near Village - Sihi Dwarka Expressway , Gurgaon - Haryana -122004	Test Report No.	EES/2024/1104
	Date of Report	08/07/2024
	Work Order No.	EES/2024-2025/0314
	Period of testing	06/07/2024 to 08/07/2024
	Type of Sample	STP Treated Water
	Date of Received	06/07/2024
	Sample Received By.	Mr. Basant kumar
Customer Ref.	EES/2024-2025/0314	
Description of Sample.	One water sample was received by us on 06/07/2024.	
Sample Code /Locations.	STP -Treated Water Sample M/s Krisumi Corporation Pvt. Ltd.	

Test Results.

Sr. No.	Test Parameters	Unit	Test Results	Specification, standard (method) or technique used.	Permissible Limits as per IS:456:2000
1	pH value @ 25 Deg. C	-	7.22	IS:3025(Part-11)	Not less than 6.0
2	Acidity	To neutralize 100 ml	0.2ml	IS:3025 (Part-22)	To neutralize 100 ml sample of water, using Phenolphthalein as an indicator, it should not Require more than 5 ml of 0.02 normal NaOH.
3	Total Alkalinity	To neutralize 100 ml	3.4ml	IS:3025 (Part-23)	To neutralize 100 ml sample of water, using the mixed indicator, it should not Require more than 25 ml of 0.02 normal H2SO4
4	Organic Solids	mg/l	30.16	IS:3025 (Part-18)	200max.
5	Inorganic Solids	mg/l	718.84	IS:3025 (Part-18)	3000max.
6	Sulphates as SO4	mg/l	76	IS:3025 (Part-24)	400max.
7	Chloride as Cl	mg/l	263	IS:3025 (Part-32)	2000max.
8	Suspended matter	mg/l	12.8	IS:3025 (Part-17)	2000max.

Remarks/Opinion:- The above tested parameters are under the specified limits as per IS: 456:2000 and water sample confirm as per IS:456:2000 clause 5.4 for construction purpose.

Conditions:-

- ✓ The above mentioned results relates to the tests specified by the customer for the given sample.
- ✓ The test report shall not be reproduced except in full, without the written approval of the Laboratory.
- ✓ This test report shall not be used in any advertising media or as evidence in the Court of Law without prior written consent of Laboratory.
- ✓ The test sample will be disposed off after two weeks from the date of issue of report

---End of report---

