

Patwari

# Tax Invoice

**ECOTECH SERVICES INC...**  
 ( Analytical Laboratory Division )  
 Plot No.99, G.No.4, Navlu Colony, Railway Station Road Ballabgarh-Faridabad-121004  
 (Haryana).Tel.+91-129-4630926,9650160159,9911378912  
 E-mail:- ecofbd@yahoo.com,info@ecotechservices.in ,www.ecotechservices.in  
 MSME -UDYAM-HR-03-0021507 | Format Code No.ESI/ALD/NABL/34  
 GSTIN:06AIHPC6825A1ZS {State Code: HR (06) } SAC CODE: 998346

Date: 4 September 2023  
 Invoice No.: ESI/23-24/0428  
 Order No.: ESI/23-24/0479  
 Salesperson: R.Chauhan  
 Tracking Ref.: Mr. Rambir M.No. 9818882358

Bill To:  
 M/s Krisumi Corporation Pvt. Ltd  
 Sector-36A , Near Village - Sihi Dwarka  
 Expressway ,Gurgaon - Haryana -122004  
 GSTIN NO. 06AAECV0565A1ZR

Ship To:  
 Sector-36A , Near Village - Sihi Dwarka  
 Expressway ,Gurgaon - Haryana -122004  
 GSTIN NO. 06AAECV0565A1ZR

Qty	Item	Description	Unit Price	Tax	Total
1	ESI0142	STP Outlet Const. water testing as per IS: 456 :-Ph,Acidity,Alkalinity,Organic Solids, Inorganic Solids,Chloride,Sulphate ,Suspended material .	Rs.2,000.00	GST@18%	Rs.2,000.00

*Handwritten notes:*  
 GMDA H N.O.C  
 TEST  
 Report on 31/8/23

Subtotal Rs.2,000.00  
 CGST@9% Rs.180.00  
 SGST@9% Rs.180.00  
**Total Rs.2,360.00**  
**Balance Due Rs.2,360.00**

Note:- 01 STP Treated water sample received on 31/08/2023.

**Terms & Conditions :**

- 1.Type of Services: Technical Testing and Analysis Services. SAC CODE :998346
- 2.PAN Number: AIHPC6825A.
- 3.BANK : AXIS BANK LTD ,A/C. 911020037661668,IFS CODE- UTIB0000039 (RTGS, IMPS & NEFT)
- 4.Branch: Ballabgarh -SCO 40, Sector-7, Ballabgarh-Faridabad-121006.
- 5.Payment by Cheque/Bank draft /on line net banking beneficiary Name "ECOTECH SERVICES INC." FARIDABAD
- 6.This Tax Invoice Issued under GST Act-2017 (Govt. of India)
- 7.All disputes will subject to Faridabad court only.
8. Under the Section -15 of MSMED -Act-2006(Payment Terms-Make Payment with in 15 days of acceptance of Goods or Services.

for ECOTECH SERVICES INC...  
  
**R. Chauhan**  
 (Auth.Signatory)



# ECOTECH SERVICES INC... (Analytical Laboratory Division)

ISO 9001:2015 ISO 14001:2015 | OHSMS - ISO 45001:2018 Certified  
Members of Association of Indian Laboratories (AOIL) & IAM SME of India.

Plot No. 99, Gall No. 04, Navlu Colony, Railway Station Road,  
Ballabgarh - 121004, Faridabad (Haryana)  
Phone No. +91-129-4630926, M: 9650160159, 9911378912

E-mail: ecotbd@yahoo.com, info@ecotechservices.in  
Website: www.ecotechservices.in  
MSME No.: UDYAM-HR-03-0021507

## TEST REPORT

Test Report Issued To:- M/s Krisumi Corporation Pvt. Ltd Sector-36A, Near Village - Sihi Dwarka Expressway, Gurgaon - Haryana -122004	Test Report No. 0013275 Date of Report 04/09/2023 Work Order No. ESI/23-24/0479 Period of testing 31/08/2023 to 04/09/2023 Type of Sample STP Treated Water Date of Received 31/08/2023 Sample Received By. Mr. Basant kumar Customer Ref. ESI/23-24/0479
Description of Sample.	One water sample was received by us on 31/08/2023.
Sample Code /Locations.	STP -Treated Water Sample M/s Krisumi Corporation Pvt. Ltd.

### Test Results.

Sr. No.	Test Parameters	Unit	Test Results	Specification, standard (method) or technique used.	Permissible Limits as per IS:456:2000
1	pH value @ 25 Deg. C	-	7.54	IS:3025(Part-11)	Not less than 6.0
2	Acidity	To neutralize 100 ml	0.2ml	IS:3025 (Part-22)	To neutralize 100 ml sample of water, using Phenolphthalein as an indicator, it should not Require more than 5 ml of 0.02 normal NaOH.
3	Total Alkalinity	To neutralize 100 ml	3.9ml	IS:3025 (Part-23)	To neutralize 100 ml sample of water, using the mixed indicator, it should not Require more than 25 ml of 0.02 normal H2SO4
4	Organic Solids	mg/l	184.50	IS:3025 (Part-18)	200max.
5	Inorganic Solids	mg/l	654.50	IS:3025 (Part-18)	3000max.
6	Sulphates as SO4	mg/l	85	IS:3025 (Part-24)	400max.
7	Chloride as Cl	mg/l	301	IS:3025 (Part-32)	2000max.
8	Suspended matter	mg/l	18.6	IS:3025 (Part-17)	2000max.

Remarks/Opinion:- The above tested parameters are under the specified limits as per IS: 456:2000 and water sample confirm as per IS:456:2000 clause 5.4 for construction purpose.

#### Conditions:-

- ✓ The above mentioned results relates to the tests specified by the customer for the given sample.
- ✓ The test report shall not be reproduced except in full, without the written approval of the Laboratory.
- ✓ This test report shall not be used in any advertising media or as evidence in the Court of Law without prior written consent of Laboratory.
- ✓ The test sample will be disposed off after two weeks from the date of issue of report

---End of report---

Mohabam

