

Tax Invoice



Dev Electrical & Air Conditioning Solutions

Plot No 45, Sec 15 Part 2 Patel Nagar Gurgaon Gurgaon Haryana 122001
 +91-9999247160 , ajaythakur@develectrical.in
 GSTIN: 06CTDPK6941A1ZZ State : Haryana
 Place Of Supply: Haryana

Invoice No: 23-24/0309
 Invoice Date: Thu Mar 21 2024
 Due Date: Thu Mar 28 2024

Bill To (Buyer)				Ship To (Consignee)			
KRISUMI CORPORATION PRIVATE LIMITED Sec 36 A, Gurugram, Haryana, 122001 GSTIN: 06AAECV0565A1ZR State: Haryana				KRISUMI CORPORATION PRIVATE LIMITED Sec 36 A, Gurugram, Haryana, 122001, 122001			
#	Item & Description	HSN	QTY	Rate/Item	Taxable Value	GST	Amount
1	Split AC No 3 gas top up charge	8415	1 NOS	1,500	1,500	270 (18%)	1,770
2	Split AC No 8 Nitrogen Filling charge	8415	1 NOS	650	650	117 (18%)	767
3	Gas Refilling charge R 32	8415	1.5 TON	1,800	2,700	486 (18%)	3,186
SUB TOTAL			3.5 QTY		₹ 4,850	₹ 873	₹ 5,723

Salesperson:
Ajay Thakur

Bank Details

A/c Holder Name: Dev Electrical & Airconditioning Solutions
 A/C. Number: 016185800003121
 IFSC Code: YESB000161
 Branch: Yes Bank Gr. Floor Unit No 004, Unitech Trade Centre ,Sushant Lok 1 Gurgaon
 UPI ID: ajay25kumar1987@ybl

Taxable Amount	4850
Total Tax	873
Total Payable Amount	₹ 5,723
Remaining Balance	₹ 5,723

Total Payable Amount: Five Thousand Seven Hundred And Twenty-Three Rupee Only

HSN & Tax Breakup

#	HSN/SAC	Taxable Value	Central GST (C)		State GST (S)		Cess		Total Tax
			Rate (%)	Amount (₹)	Rate (%)	Amount (₹)	Rate (%)	Amount (₹)	
1	8415	4,850	9%	436.5	9%	436.5	0%	0	873
Total		₹ 4,850		₹ 436.5		₹ 436.5		₹ 0	₹ 873

Terms & Conditions:

- Goods once sold will not be taken back.
- GST Extra As per Actual
- 50% Advanced Payment



Scan & Pay using any UPI App

For Dev Electrical & Air Conditioning Solutions

Ajay Thakur

Authorised Signatory



Invoice created by Treflo App (www.treflo.com)

GATE IN
 NO. 2689
 DATE 26-3-24
 KRISUMI CORPORATION

HPS

Manish
 21/03/24

Customer Service Report

GST No - 06CTDPK691A1ZZ



DEV ELECTRICALS & AIR CONDITIONING SOLUTIONS

Plot No 45, Sec 15 Part 2, Patel Nagar Gurgaon

Email : dev.airconditioning.solution1987@gmail.com / ajaythakur@develectrical.in

Contact : +91 9999247160, +91 9785235333, +91 8130539373

211

Deals in:- Electrical work of commercial building and warehouses, all type Air Conditioning
CCTV, Fire Detection System Installation Repairing and servicing work, Equipment commissioning work.

Date :- <u>21-03-24</u>	Warranty	AMC	<input checked="" type="checkbox"/> Chargeble
-------------------------	----------	-----	---

Nature of Work :- AC Work.

Details of Customer:- Krisumai
See 36A, Gurgaon.

Mob:-

Defect Found

Daikin inverter AC R-32 gas fill unit no-8.

Unit NO-1, unit NO-7 and 9 work pending.

Action Taken

Checked & filled nitrogen pressure 400 psig and bound suction line. Flare nut leak due to copper pipe tilt and alignment of flare nut and gas R-32 changed and now AC is working.

Machine No :- <u>3P669214-3A</u>	Parts Related:- <u>NO</u>
Located :- <u>Project office</u>	Unit Part to be taken to Workshop :- <u>NO</u>
Service Engineer :- <u>Harish</u>	Complaint Rectified:- <u>Yes</u>

Voltage - 219V (Volts) Load in Amp 6.1 A

Technician Remarks:-	Customer Remarks:-
----------------------	--------------------

Engineer Name :- <u>Harish</u>	Customer Name - <u>Manish</u> <u>21/03/24</u>
--------------------------------	--